



Asbestos Inventory

This information is provided to ensure appropriate procedures are followed to protect the University community, environment, and visitors from the potential hazards of asbestos-containing materials (ACM). This inventory includes identified asbestos-containing materials in University Buildings constructed prior to 1980.

Specific locations of asbestos-containing materials can be obtained by contacting ESSR at 301-405-3960.

DO NOT PRINT THIS LISTING AND ASSUME CHANGES NEVER OCCUR. THE INVENTORY IS FREQUENTLY UPDATED.

IF A BUILDING OR MATERIAL IS NOT SHOWN ON THIS LISTING, DO NOT ASSUME THERE IS NO ASBESTOS PRESENT.

The following materials are assumed to be ACM until proven otherwise by laboratory analysis. Samples may only be collected by licensed ESSR staff.

Presumed asbestos-containing materials (PACM) in all buildings:

- Roofing materials
- Cement sheet products
- Fire doors
- Non-rubber gaskets/seals
- Spackling
- Caulk
- Duct mastic
- Non-fiberglass thermal system insulation
- Plaster
- Laboratory countertops
- Classroom chalk boards
- Drywall/joint compound

Building #001

Energy Plant

- Boiler insulation
- Pipe insulation
- Mudded pipe fittings

Building #003

Service Building

- Non-fiberglass pipe insulation
- Mudded fittings
- Spackling
- Cement board
- Floor sheeting
- Floor sheeting underneath carpeting
- Green 9"x9" floor tile and mastic
- Grey linoleum sheet flooring
- Black floor mastic
- Dark brown ceiling tile adhesive

Building #004

Ritchie Coliseum

- Note PACM list above

Building #007

Pocomoke Building

- Exterior flashing

Building #009

Memorial Chapel

- Parging plaster, underlying brick, and CMU (PACM)
- Firestopping insulation (PACM)
- Ceiling surfacing material
- 9"x 9" black floor tile
- Caulk
- Black/white 12" x 12" floor tile
- Black mastic

Building #011

- Door frame caulk
- Off-white spackle/joint compound
- Mudded fittings
- 9" x 9" peach floor tile
- 9" x 9" green floor tile
- Black mastic

Building #014

Harford Hall

- Ceiling tile adhesives
- Black floor mastic
- Tan baseboard adhesive
- Pipe insulation behind walls

Building #015

Calvert Hall

- Asbestos rope (pipe wrap)
- Dark brown ceiling tile adhesive
- Firestopping associated with steam riser pipes

Building #016

Baltimore Hall

- Caulk

Building #017

Cecil Hall

- Ceiling tile adhesive
- Duct insulation
- Ceiling tiles (white with red backing)
- 9" x 9" dark grey/beige floor tile
- 9" x 9" grey floor tile
- Black mastic

Building #020

Motorcycle Storage Building

Suspect materials not identified. Materials exposed during future renovation/demolition projects may require additional assessment. Refer to PACM list.

Building #021

Prince Georges Hall

- Grey/beige cement
- Dark brown ceiling tile adhesive
- 9" x 9" black/white floor tile
- Black mastic

Building #022

Kent Hall

Suspect materials not identified. Materials exposed during future renovation/demolition projects may require additional assessment. Refer to PACM list.

Building #023

Washington Hall

- 9" x 9" off-white floor tile
- Black mastic

Building #024

Allegany Hall

- Black mastic
- Dark brown ceiling tile adhesive

Building #025

Charles Hall

- White pipe mastic
- Tan caulk
- White caulk

Building #026

South Campus Dining Hall

- Gray/beige window caulk
- White spackle on drywall
- Non-fiberglass pipe insulation
- Non-fiberglass tank insulation
- Mudded fittings
- White (red back) ceiling tile
- 12" x 12" olive/gray floor tile
- 12" x 12" off-white floor tile
- Black mastic

Building #028

Howard Hall

- Gray window frame caulk

Building #029

Frederick Hall

- Floor tiles
- Black floor mastic
- Non-fiberglass pipe insulation
- Mudded fittings
- Black wall mastic

Building #030

Talbot Hall

- 9" x 9" black/red floor tile
- Black floor tile mastic

Building #031

Garrett Hall

- Dark brown ceiling tile adhesive

Building #032

Montgomery Hall

- Beige caulk
- Black floor mastic

Building #034

Jimenez Hall

- Gray caulk
- Joint compound/drywall
- Brown baseboard adhesive on black vinyl baseboard
- Brown ceiling tile adhesive
- Non-fiberglass pipe insulation
- Non-fiberglass tank insulation
- Mudded joints
- 9" x 9" grey floor tile
- 9" x 9" beige floor tile
- 9" x 9" grey/beige floor tile
- 9" x 9" blue floor tile
- 12" x 12" brown floor tile
- 12" x 12" off-white floor tile
- Black floor mastic

Building #035

McKeldin Library

- Grey window caulk
- 9" x 9" off-white floor tile
- 9" x 9" grey floor tile
- Magenta/beige floor sheeting
- Black floor mastic

Building #037

Shoemaker Building

- Brown paper/metal foil duct wrap
- Brown cardboard duct wrap
- Joint compound/drywall
- Grey radiator barrier/wall insulation

Building #038

Lefrak Hall

- 12" x 12" yellow/beige floor tile
- 12" x 12" beige floor tile
- 12" x 12" grey/beige floor tile
- Black floor mastic
- Roof flashing
- Built-up roofing material

Building #040

Morrill Hall

- 9" x 9" black floor tile
- 9" x 9" red/brown floor tile
- Black floor mastic

Building #042

Tydings Hall

- Cementitious wall board
- Metal foil on brown paper duct wrap and associated white mastic
- Spray-on encapsulant residue
- Non-fiberglass tank insulation
- Non-fiberglass pipe insulation
- Black pipe wrap
- Grey/beige fire stopping
- Grey vibration joints
- Mudded joints
- 9" x 9" pink floor tile
- 9" x 9" cream floor tile
- 9" x 9" dark green floor tile
- 9" x 9" peach floor tile
- 9" x 9" light grey floor tile
- 12" x 12" dark green floor tile
- 12" x 12" beige with black and white stripes floor tile
- 12" x 12" light green floor tile
- Black floor mastic

Building #043

Taliaferro Hall

- Asphaltic fibrous radiator insulation
- Exterior stucco ceilings
- Mudded fittings
- 9" x 9" off-white/brown floor tile
- 9" x 9" green floor tile
- Black floor mastic

Building #044

Skinner Building

- 9" x 9" beige/black floor tile
- 9" x 9" black/red floor tile
- 9" x 9" beige floor tile
- Black floor mastic
- 2' x 4' ceiling tiles with pinhole pattern

Building #045

Instructional Television Facility

- See PACM list

Building #046

Marie Mount Hall

- Duct wrap
- Dark grey fume hood panel
- Non-fiberglass pipe insulation
- Mudded fittings
- Pipe wrap with white mastic
- Black lab countertops and black adhesive
- Brown ceiling tile adhesive
- 12" x 12" tan floor tile
- 12" x 12" orange floor tile
- 12" x 12" beige floor tile
- 12" x 12" cream floor tile
- 12" x 12" off-white floor tile
- Black floor mastic

Building #047

Woods Hall

- Ceiling tile adhesive, brown
- Non-fiberglass pipe insulation
- Mudded joints
- 9" x 9" peach floor tile
- 9" x 9" red/brown floor tile
- Black floor mastic

Building #048

Francis Scott Key Hall

- Drywall/joint compound
- Black duct mastic
- Brown paper/metal foil pipe wrap
- Non-fiberglass pipe insulation
- Mudded joints
- Cement board
- plaster
- 9" x 9" grey floor tile
- 9" x 9" grey/green floor tile
- 9" x 9" beige/pink floor tile
- Black floor mastic

Building #051

Worcester Hall

- White door frame caulk
- Tan/white window frame caulk
- Mudded fittings
- Green stair tread
- 9" x 9" cream floor tile
- 9" x 9" grey/green floor tile
- 9" x 9" grey/beige floor tile
- 9" x 9" olive floor tile
- 9" x 9" grey floor tile
- 9" x 9" brown floor tile
- 12" x 12" brown floor tile
- Grey floor sheeting (under carpet)
- Black floor mastic

Building #052

Clarence M. Mitchell, Jr. Building

- Note: ACM floor tiles have been covered with carpeting in some locations
- Brown ceiling tile adhesive
- Beige ceiling tile adhesive
- Non-fiberglass pipe insulation
- Mudded fittings
- Black mastic on pipe wrap
- 9" x 9" beige floor tile
- 9" x 9" black/white floor tile
- 9" x 9" yellow floor tile
- 9" x 9" beige/tan floor tile
- 9" x 9" beige/red-brown floor tile
- 9" x 9" brown floor tile
- 9" x 9" orange floor tile
- 9" x 9" peach floor tile
- Black floor mastic

Building #054

Preinkert Hall

- Brown ceiling tile adhesive
- Black base cove
- Black base cove mastic
- Non-fiberglass pipe insulation
- Non-fiberglass tank insulation
- Mudded joints
- Vibration joints
- 2' x 4' ceiling tile (white with red back)
- 9" x 9" red floor tile
- 9" x 9" dark brown floor tile
- 9" x 9" beige/green floor tile
- 9" x 9" peach floor tile
- 9" x 9" grey floor tile
- Black floor mastic

Building #060

Anne Arundel Hall

- Inaccessible thermal system insulation in pipe chases

Building #062

St. Marys Hall

- Brown floor tile
- Black floor mastic

Building #064

Dorchester Hall

- Brown ceiling tile adhesive
- 9" x 9" brown floor tile
- 9" x 9" grey/beige floor tile
- 9" x 9" light brown floor tile
- 9" x 9" green/beige/black floor tile
- Black floor mastic

Building #065

Carroll Hall

- Brown ceiling tile adhesive
- Drywall/joint compound
- Non-fiberglass pipe insulation
- Mudded fittings
- Window glazing
- Window caulk
- 9" x 9" black floor tile
- 9" x 9" black/grey floor tile
- 9" x 9" black/green floor tile
- 9" x 9" black/olive floor tile
- Black floor mastic

Building #069

Wicomico Hall

- Non-fiberglass pipe insulation
- Mudded fittings
- 12" x 12" black/grey floor tile
- 12" x 12" off-white floor tile
- 9" x 9" black/grey floor tile
- 9" x 9" dark brown floor tile
- 9" x 9" black/green floor tile
- 9" x 9" grey floor tile
- Black floor mastic

Building #070

Caroline Hall

- 9" x 9" black/grey floor tile
- 9" x 9" green/olive floor tile
- 9" x 9" black/green floor tile
- 9" x 9" grey floor tile
- Black floor mastic

Building #071

Lee Building

- Window caulk
- Cement wall control joints
- Exterior chiller drain pit corrugated pipe
- Mudded fittings
- 9" x 9" off-white floor tile
- Black floor mastic

Building #073

H.J. Patterson Hall

- Drywall and joint compound
- Brown baseboard adhesive
- Non-fiberglass pipe insulation
- Mudded fittings
- 9" x 9" off-white floor tile
- 9" x 9" grey floor tile
- Magenta-beige floor sheeting
- Black floor mastic

Building #076

Symons Hall

- Sewer line gasket
- Plaster
- Brown baseboard adhesive
- Dark brown ceiling tile adhesive
- 2' x 4' white (red backed) ceiling tile
- Non-fiberglass pipe insulation
- Mudded fittings
- 9" x 9" black/grey floor tile
- 9" x 9" black/beige floor tile
- Black floor mastic

Building #077

Main Administration

- White duct mastic
- Black duct mastic
- Brown/black baseboard adhesive
- Brown ceiling/wall tile adhesive
- Non-fiberglass pipe insulation
- Mudded fittings
- Grey acoustical insulation

Building #078

Reckord Armory

- Pipe penetration filler (wall plug)
- Black duct mastic
- Brown ceiling/wall adhesive
- Non-fiberglass pipe insulation
- Fabric vibration joints
- Grey cement board
- 9" x 9" red/brown floor tile
- 9" x 9" magenta/brown floor tile
- 9" x 9" white floor tile
- 9" x 9" off-white floor tile
- 12" x 12" red floor tile
- Black floor mastic

Building #079

Turner Hall

- 2' x 4' ceiling tile
- Red floor leveling compound
- Caulk between cement panels
- Silver/brown duct cover
- Grey stair tread
- Grey cement board
- Silver/brown pipe wrap
- 9" x 9" black/red floor tile
- Black floor mastic

Building #080

Rosborough Inn

- Roof flashing adhesive
- White window caulk
- Yellow sheet resilient flooring
- 12" x 12" grey/beige floor tile
- 12" x 12" light green/brown floor tile
- Black floor mastic

Building #081

Wind Tunnel

- Brown/black on exterior wall of wind tunnel
- Brown ceiling tile adhesive
- White window caulk
- Window glazing
- Non-fiberglass insulation
- Non-fiberglass tank insulation
- Mudded fittings
- Grey duct insulation
- 9" x 9" black floor tile
- 9" x 9" green floor tile
- 12" x 12" brown floor tile
- 9" x 9" red/brown floor tile
- Black floor mastic

Building #082

John S. Toll Physics Building

- Duct covering
- Duct insulation
- Black duct mastic
- Vibration joints
- Beige ceiling plaster
- 2' x 2' ceiling tiles
- Cement board
- Non-fiberglass pipe insulation
- Mudded fittings
- 12" x 12" green floor tile
- 12" x 12" dark green floor tile
- 12" x 12" cream floor tile
- 12" x 12" off-white floor tile
- 9" x 9" green floor tile
- 9" x 9" white floor tile
- 9" x 9" dark grey floor tile
- 9" x 9" beige floor tile
- 9" x 9" beige marble floor tile
- 9" x 9" black/beige floor tile
- 9" x 9" grey/green floor tile
- 9" x 9" grey/brown floor tile
- 9" x 9" rose floor tile
- 9" x 9" rose/black floor tile
- 9" x 9" dark brown floor tile
- 9" x 9" grey floor tile
- 9" x 9" light grey floor tile
- 9" x 9" tan floor tile
- 9" x 9" black floor tile
- 9" x 9" off-white floor tile

- 9" x 9" peach floor tile
- Beige linoleum floor sheeting
- Black floor mastic

Building #083

J.M. Patterson Building

- Beige fabric duct wrap
- Drywall/joint compound
- Non-fiberglass pipe insulation
- Mudded fittings
- 12" x 12" grey floor tile
- 12" x 12" brown floor tile
- 12" x 12" light green floor tile
- Black floor mastic

Building #084

William E. Kirwan Hall

- White plaster
- Grey plaster
- 12" x 12" tan floor tile
- 12" x 12" red/brown floor tile
- 9" x 9" red floor tile
- 12" x 12" peach floor tile
- 12" x 12" off-white floor tile
- 12" x 12" grey/brown floor tile
- 12" x 12" grey/green floor tile
- 12" x 12" grey/beige floor tile
- 12" x 12" dark brown floor tile
- 12" x 12" beige floor tile
- Black floor mastic

Building #085

Institute for Physical Science and Technology

- Non-fiberglass pipe insulation
- Mudded fittings
- Grey duct insulation
- 9" x 9" yellow/beige floor tile
- 9" x 9" red/brown floor tile
- 9" x 9" peach floor tile
- 9" x 9" grey/beige floor tile
- 12" x 12" orange/white floor tile
- 9" x 9" grey floor tile
- 12" x 12" beige floor tile
- White sheet resilient flooring
- Black floor mastic

Building #087

Central Animal Resources Facility

- Grey hood liners

Building #088

Martin Hall

- Cement panel in laboratory fume hoods
- Grey/black caulk
- 12" x 12" black floor tile

Building #089

Engineering Laboratory Building

- Black duct mastic
- Drywall/joint compound
- Black laboratory counter caulk
- Non-fiberglass pipe insulation
- Non-fiberglass tank insulation
- Dark grey pressure tank waterproofing sealant
- Mudded fittings
- 2' x 2' Cement ceiling panels
- 2' x 4' ceiling tile
- 12" x 12" white/grey floor tile
- 12" x 12" white floor tile
- 12" x 12" grey floor tile
- 12" x 12" dark brown floor tile
- 12" x 12" cream floor tile
- 9" x 9" black floor tile
- Black floor mastic

Building #090

Chemical and Nuclear Engineering Building

- Drywall/joint compound
- Grey/beige laboratory counters
- Brown laboratory counters
- Black laboratory counters
- Sink caulk
- Black laboratory counter adhesive
- Tan laboratory counter adhesive
- Cementitious fume hood cabinet
- Ceiling tiles
- Non-fiberglass pipe insulation
- Non-fiberglass tank insulation
- Mudded fittings
- 12" x 12" red/brown floor tile
- 12" x 12" grey floor tile
- 9" x 9" dark grey floor tile
- 9" x 9" black floor tile

- Maroon cementitious floor sheeting
- Black floor mastic

Building #091

Chemistry Building

- Cementitious fume hood paneling and duct work
- Duct sealant
- Cement board wall/ceiling panels covering hallway pipe chases
- Beige window frame caulk
- Non-fiberglass pipe insulation
- Mudded fittings
- Vibration joints
- Brown baseboard mastic
- White rubbery paint
- 2' x 4' ceiling tile
- Black/grey wall/ceiling paper sheathing
- 9" x 9" olive floor tile
- 12" x 12" off-white floor tile
- 9" x 9" off-white floor tile
- 9" x 9" grey floor tile
- 12" x 12" grey floor tile
- 9" x 9" green floor tile
- 9" x 9" dark brown floor tile
- 9" x 9" brown floor tile
- 9" x 9" beige floor tile
- Black floor mastic

Building #092

Potomac Building

- Cementitious laboratory fume hood panels
- Brown ceiling tile adhesive
- Mudded fittings
- 9" x 9" off-white/brown floor tile
- 9" x 9" off-white floor tile
- 9" x 9" brown floor tile
- Grey floor mastic
- Black floor mastic

Building #093

Engineering Annex

- White caulk
- White flexible floor sheeting
- Black floor mastic

Building #096

Cambridge Hall

- Brown paper pipe wrap
- Mudded fittings with black mastic
- Brown ceiling tile adhesive
- 9" x 9" off-white floor tile with inky black streak
- 9" x 9" tan floor tile
- 9" x 9" magenta/grey floor tile
- 9" x 9" green floor tile
- 9" x 9" cream floor tile
- 9" x 9" blue/grey floor tile
- 9" x 9" blue/green floor tile
- 9" x 9" black/grey floor tile
- Black floor mastic

Building #097

Cambridge Community Center

- Ceiling tile sections over crown molding in east wing 1
- Ceiling tiles
- Ceiling tile adhesive
- Asphaltic duct sealant
- Linoleum paper backing
- Floor tile
- Wall plaster
- Floor tile mastic
- HVAC vibration isolator cloth
- 9" x 9" floor tile

Building #098

Centreville Hall

- Ceiling tiles
- Off-white fabric vibration joints
- 9" x 9" white/brown floor tile
- 9" x 9" grey/tank floor tile
- 9" x 9" black/grey floor tile
- 9" x 9" beige floor tile
- Black floor mastic

Building #099

Bel Air Hall

- Dark brown ceiling tile adhesive
- Beige floor sheeting (some under carpeting)
- 9" x 9" tan/cream floor tile
- 9" x 9" tan floor tile
- 9" x 9" grey/beige floor tile
- green floor tile
- 9" x 9" dark grey floor tile
- 9" x 9" cream/beige floor tile
- Black floor mastic

Building #103

Animal Science Service Building

- White spackling
- Grey cement board
- White chimney caulk
- 9" x 9" brown floor tile
- Black floor mastic

Building #111

Physics Welding Shop

- Window caulk

Building #121

Chestertown Hall

- Brown ceiling tile adhesive
- 9" x 9" yellow/beige floor tile
- 9" x 9" tan floor tile
- 9" x 9" pink/olive floor tile
- 9" x 9" light grey floor tile
- 9" x 9" grey/beige floor tile
- 9" x 9" dark grey floor tile
- 9" x 9" blue/grey floor tile
- 9" x 9" black floor tile
- Black floor mastic

Building #122

Cumberland Hall

- Cream door frame caulk
- 2' x 4' ceiling tiles with red backing
- Non-fiberglass tank insulation
- Mudded fittings
- 9" x 9" peach floor tile
- 9" x 9" grey/beige floor tile
- 9" x 9" dark brown floor tile

Building #126**House 1**

- Non-fiberglass tank insulation

Building #127**House 2**

- Mudded fittings

Building #128**House 3**

- See PACM list

Building #129**House 4**

- See PACM list

Building #130**House 5**

- See PACM list

Building #131**House 6**

- See PACM list

Building #132**House 7**

- See PACM list

Building #133**House 8**

- See PACM list

Building #134**House 9**

- See PACM list

Building #135**House 10**

- See PACM list

Building #136**House 11**

- Non-fiberglass pipe insulation
- Non-fiberglass tank insulation
- Mudded fittings

Building #137

House 12

- Non-fiberglass pipe insulation
- Non-fiberglass tank insulation
- Mudded fittings

Building #138

House 13

- See PACM list

Building #139

House 14

- See PACM list

Building #141

Tawes Hall

- White duct mastic
- Spray-on insulation (enclosed)
- Non-fiberglass tank insulation
- Cement board
- Roof over Ulrich Recital Hall
- Gray pin mastic
- Gray air conditioner caulk
- 2' x 4' ceiling tiles
- Mudded joints
- 9" x 9" off-white floor tile

Building #142

Animal Sciences/Agricultural Engineering Building

- Ductwork and fume hood gaskets
- Red duct mastic
- Vibration joints
- Mudded fittings
- White non-fiberglass pipe wrap
- White duct insulation
- Grey duct cover
- Tan floor sheeting
- 9" x 9" off-white floor tile
- 9" x 9" light green floor tile
- 9" x 9" grey/beige floor tile
- 9" x 9" grey floor tile
- 9" x 9" cream floor tile
- 9" x 9" black/grey floor tile
- 9" x 9" black/beige floor tile
- 9" x 9" black floor tile
- Black floor mastic

Building #143

Benjamin Building

- Black pipe wrap adhesive
- Cement pipes and ducts
- Brown base board adhesive
- 2' x 4' white ceiling tiles
- Mudded fittings
- Black roof caulk
- Chalkboard adhesive
- 9" x 9" off-white floor tile
- 9" x 9" grey/beige floor tile
- 9" x 9" dark brown floor tile
- 9" x 9" cream/green floor tile
- 9" x 9" cream floor tile
- 9" x 9" beige floor tile
- Black floor mastic

Building #144

Biology-Psychology Building

- Dark brown ceiling tile adhesive
- Fire doors
- Grey, cementitious fume hood paneling
- Brown base board adhesive
- Black/brown metal foil/paper duct wrap
- White/beige/grey/black duct mastic
- Pipe insulation mastic
- Black laboratory countertops and associated adhesives
- Non-fiberglass chiller insulation
- Cloth vibration isolator
- Firestopping
- Wall/door caulk
- Red unit ventilator mastic
- Brown sink mastic
- Black linoleum floor sheeting
- 12" x 12" cream floor tile
- 12" x 12" grey floor tile
- 12" x 12" grey/beige floor tile
- 12" x 12" light grey floor tile
- 12" x 12" off-white floor tile
- 12" x 12" tan floor tile

Building #145

Architecture Building

- Cream caulk in ductwork
- Vibration joints
- Mudded fittings
- Cement duct

Building #146

Parren J. Mitchell Art Sociology Building

- Fire doors with white core insulation
- Brown chalkboard adhesive
- Brown base board adhesive
- Drywall/joint compound
- 12" x 12" red/brown floor tile
- 12" x 12" off-white floor tile
- 12" x 12" dark brown floor tile
- 12" x 12" brown/black/white floor tile
- Black floor mastic

Building #147

Hornbake Library

- White mastic on fiberglass pipe insulation
- Drywall/joint compound
- Non-fiberglass pipe insulation
- White door caulk
- Mudded fittings
- 12" x 12" olive floor tile
- 12" x 12" off-white floor tile
- 12" x 12" brown floor tile
- 12" x 12" blue floor tile
- 9" x 9" beige floor tile
- Black floor mastic

Building #156

Arboretum Outreach Center

- 9" x 9" black with green streaks floor tile
- 9" x 9" black floor tile
- Black floor mastic

Building #158

Varsity Sports Teamhouse

- White and grey exterior window glaze and caulk
- Ceiling tiles
- 12" x 12" off-white floor tile
- Black floor mastic

Building #159

Football Stadium

- See PACM

Building #162

Cole Student Activities Building

- Brown paper pipe and duct wrap
- Metal foil pipe and duct wrap
- Black mastic on pipes and ductwork
- White mastic on pipes and ductwork
- Grey/beige fibrous residue of abated ceiling covering on concrete ceiling
- Ceiling tile adhesive
- 2' x 4' ceiling tiles (red backing)
- White vibration joints
- Mudded fittings
- Non-fiberglass pipe insulation
- 9" x 9" olive floor tile
- 9" x 9" grey floor tile
- 9" x 9" green/black floor tile
- 9" x 9" green floor tile
- 9" x 9" dark brown floor tile
- 9" x 9" black floor tile
- Black floor mastic

Building #163

Stamp Student Union

- Ceiling tile paint
- Mudded fittings
- Valve insulation
- Non-fiberglass pipe insulation
- Duct insulation
- Cloth vibration dampers
- Black pipe and duct mastic
- Roof flashing

Building #165

Golf Course Driving Range Cont. Building

- Drywall/joint compound
- 9" x 9" beige floor tile
- Black floor mastic

Building #169

Boat House

- Refer to PACM list

Building #196

MFRI Structural Firefighting Building

- Refer to PACM list

Building #201

Leonardtown Office Building

- 9" x 9" floor tile
- Black paper sheathing between studs and drywall

Building #219

Astronomy Lecture Building

- Brown paper/metal foil duct wrap
- 12" x 12" red/brown floor tile
- Black floor mastic

Building #221

Astronomical Observatory

- 9" x 9" tan with multi-colored spots floor tile
- 9" x 9" tan with mottle floor tile
- 9" x 9" black floor tile
- Black floor mastic

Building #223

Energy Research Facility

- White mastic on pipe insulation, valve jacketing, duct, and/or tank coverings
- Non-fiberglass pipe insulation
- Mudded fittings
- 12" x 12" green/grey floor tile
- 12" x 12" white floor tile
- 12" x 12" beige floor tile
- 12" x 12" grey/brown floor tile
- 12" x 12" grey floor tile
- 12" x 12" grey/beige floor tile
- 9" x 9" grey floor tile
- 9" x 9" green floor tile

Building #227

Jull Hall

- Black tar paper and mastic on cork insulation
- Cementitious ceiling panel
- Cementitious wall panel
- 2' x 2' Ceiling tiles
- Dark brown adhesive between drywall and studs
- 9" x 9" off-white floor tile
- 9" x 9" multi-colored floor tile

Building #232**Nyumburu Cultural Center**

- 12" x 12" olive floor tile
- Black floor mastic

Building #237**Geology Building**

- 12" x 12" white floor tile
- Black floor mastic

Building #238**Leonardtwn 238**

- Transite wall panel

Buildings #239, #240, #241, #242**Leonardtwn Buildings 239, 240, 241, 242**

- See PACM list

Building #243**Leonardtwn 243**

- Brown adhesive attaching drywall to studs
- Transite paneling
- Floor tile and associated mastic

Building #244, #245, #246, #247, #248, #249**Leonardtwn Buildings 244, 245, 246, 247, 248, 249**

- See PACM list

Building #250**Leonardtwn Community Center**

- Floor tile and associated mastic

Building #251**Denton Dining Hall**

- Mudded fittings

Building #252**Denton Hall**

- Beige door frame caulk
- Mudded fittings
- Brown ceiling tile adhesive
- 9" x 9" olive floor tile
- 9" x 9" grey/beige floor tile
- 9" x 9" grey floor tile
- 9" x 9" grey/green floor tile
- Black floor mastic

Building #253

Easton Hall

- Brown ceiling tile adhesive
- Grey door frame caulk
- Beige door frame caulk
- 9" x 9" peach floor tile
- 9" x 9" off-white floor tile
- 9" x 9" magenta/brown floor tile
- Black floor mastic

Building #254

Elkton Hall

- Mudded fittings
- Beige door frame caulk
- Beige tank insulation
- Brown ceiling tile adhesive
- 9" x 9" white/tan floor tile
- 9" x 9" off-white floor tile
- 9" x 9" cream/beige floor tile
- Brown stair tread
- Black floor mastic

Building #255

School of Public Health

- Brown paper/metal foil pipe wrap
- Black pipe mastic
- Black duct mastic
- White duct mastic
- Brown base board adhesive
- Mudded fittings
- 2' x 2' ceiling tiles
- 12" x 12" tan floor tile
- 12" x 12" rose floor tile
- 12" x 12" off-white floor tile
- Black floor mastic

Building #256

Ellicott Hall

- Dark brown ceiling tile adhesive
- Floor leveling compound
- Mudded fittings
- Beige door frame caulk
- Cream window caulk
- Dark brown/black adhesive behind burlap wall covering
- 12" x 12" olive floor tile
- 9" x 9" off-white floor tile
- 9" x 9" magenta/grey floor tile
- 9" x 9" magenta floor tile
- 9" x 9" grey/brown floor tile
- 9" x 9" grey floor tile
- 9" x 9" beige floor tile
- Black floor mastic

Building #258

Hagerstown Hall

- Tan door frame caulk
- Off-white window caulk
- Black duct mastic
- Black pipe mastic
- Stair tread
- Mudded fittings
- Brown ceiling tile adhesive
- 12" x 12" white floor tile
- 12" x 12" olive floor tile
- 9" x 9" off-white floor tile
- Black floor mastic

Building #259

La Plata Hall

- Grey/beige window caulk
- Black pipe mastic
- Off-white magenta stair tread
- Dark brown ceiling tile adhesive
- 9" x 9" off-white floor tile
- 12" x 12" off-white floor tile
- 12" x 12" magenta/grey floor tile
- 9" x 9" magenta/beige floor tile
- 9" x 9" grey/brown floor tile
- 9" x 9" brown floor tile
- 9" x 9" beige floor tile
- Black floor mastic

Buildings #260, #261, #263, #264, #265, #266, #267, #268, #269, #270, #271, #272, #273, #274, #275, #276, #277, #278, #279, #280, #281, #282, #283, #284, #285, #286, #287, #288, #289, #290, #291, #292

- These buildings have not been fully characterized
- See PACM list
- These buildings are managed by Southern Management Corporation

Building #299

Gate House

- See PACM list

Building #311

Elkins Building

- Mudded fittings
- Floor tile

Buildings #312, #313, #314, #319, #320

Golf course chemical storage, storage (2), fertilizer shed, and repair shop buildings

- See PACM list

Building #318

Golf Course Toilet Facility

- Window caulk

Building #332

Anacostia Building

- White duct mastic
- 9" x 9" grey floor tile
- 9" x 9" cream floor tile
- Black floor mastic